

Message Text

CONFIDENTIAL

PAGE 01 TUNIS 07506 051425Z

41

ACTION SY-04

INFO OCT-01 AF-04 EUR-12 NEA-06 ISO-00 OCE-00 CCO-00 OCL-00

FBO-02 A-01 /030 W

----- 090748

R 051400Z DEC 74

FM AMEMBASSY TUNIS

TO SECSTATE WASHDC 7632

INFO AMEMBASSY BEIRUT

AMEMBASSY ACCRA

AMEMBASSY LONDON

C O N F I D E N T I A L TUNIS 7506

BEIRUT FOR RSS AND RTC

DEPT FOR SY/FO

ACCRA FOR RCO

LONDON FOR ATO

E.O. 11652: GDS

TAGS: ASEC

SUBJECT: CCC SITE SURVEY - TUNIS

1. SITE SURVEY FOR RENOVATION AND EXPANSION OF
EXISTING CCC IN TUNIS WAS COMPLETED ON FRIDAY NOV 22.

2. RECOMMENDATIONS FOR PHYSICAL SECURITY IMPROVE-
MENTS IN C&R AREA ARE AS FOLLOWS:

A. ALL ACOUSTICAL TILE BE REMOVED FROM CEILINGS
AND WALLS OF PARENT ROOM, RESURFACE AND PAINT.

B. ALL EXCESS WIRING OF UNKNOWN ORIGIN BE REMOVED
AND NECESSARY WIRING BE ENCLOSED IN SURFACE MOUNT
CONDUIT AND HOLES IN WALL BE FILLED WITH CEMENT.

CONFIDENTIAL

CONFIDENTIAL

PAGE 02 TUNIS 07506 051425Z

C. FRESH AIR INTAKE FOR ENCLOSURE BE VENTED THROUGH

THE WALL AND PROTECTED WITH 5/8 IN. BARRED METAL GRATE.

D. MODEL III INCINERATOR BE REMOVED FROM PRESENT LOCATION IN C&R/TCU COMMON AREA AND RELOCATED ON 4TH FLOOR IN EXISTING INCINERATOR ROOM (NOW HOUSES MODEL I).

E. MODEL 1012 AND SOUND ENCLOSURE BE INSTALLED IN AREA NOW OCCUPIED BY MODEL II AND BE UTILIZED BY BOTH C&R AND TCU.

F. REMOVE EXISTING NONFUNCTIONAL KIDDE ALARM HEADS IN PARENT ROOM AND REPLACE WITH ADVISOR SERIES ALARM HEADS WIRED INTO EXISTING ADVISOR V SYSTEM.

3. TCU AREA IMPROVEMENTS:

A. REMOVE EXISTING FIRE DOOR AND REPLACE WITH METAL CLAD SOLID CORE DOOR.

B. RECOMMENDATIONS 2 A AND B APPLY TO THIS AREA AS WELL.

C. TWO EXISTING DOORS AND ALL WINDOWS IN NEW AREA TO BE INCLUDED IN VAULT EXPANSION WILL HAVE TO BE BLOCKED WITH CONCRETE AND BRICK PRIOR TO WALL REINFORCEMENT.

D. IN ORDER TO EXPAND VAULT AREA TO INCLUDE ADJACENT ROOM, ALL NEW WALLS TO BE INCLUDED IN VAULT AREA WILL HAVE TO BE REINFORCED WITH 4 IN. CONCRETE BLOCK REINFORCED WITH 5/8 REBAR ON 5 IN. CENTERS AND WELDED PER SECURITY SPECIFICATIONS AS SET FORTH IN SKAG 1-B. PRESENT EXTERIOR WALLS APPROXIMATELY 10. IN. THICK.

E. CHASTITY BELT PRESENTLY INSTALLED IN OFFICE ADJACENT TO AREA OF EXPANSION WILL HAVE TO BE MODIFIED DUE TO RELOCATION OF EXISTING OFFICE DOOR.

CONFIDENTIAL

CONFIDENTIAL

PAGE 03 TUNIS 07506 051425Z

F. CLASS 5 MOSLER VAULT DOOR SHOULD BE SERVICED AND INSPECTED FOR PROPER INSTALLATION, AS IT APPEARS TO HAVE EXTREME CLEARANCE BETWEEN WALLS AND FRAME.

4. PERSONNEL AND MATERIAL REQUIREMENTS BEING DEVELOPED BY RTC BEIRUT AND WILL BE FORWARDED UPON COMPLETION. PRESENT ESTIMATE FOR SEABEE TEAM IS FOR MINIMUM OF SIX WEEKS FOR A 3-MAN TEAM.

5. CCC SITE SURVEY REPORT BEING FINALIZED BY RCO.
SEELYE

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 05 DEC 1974
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Authority: izenbei0
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 28 MAY 2004
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1974TUNIS07506
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: GS
Errors: N/A
Film Number: D740353-0333
From: TUNIS
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1974/newtext/t19741256/aaaabwcn.tel
Line Count: 118
Locator: TEXT ON-LINE, ON MICROFILM
Office: ACTION SY
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators:
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: n/a
Review Action: RELEASED, APPROVED
Review Authority: izenbei0
Review Comment: n/a
Review Content Flags:
Review Date: 26 JUN 2002
Review Event:
Review Exemptions: n/a
Review History: RELEASED <26 JUN 2002 by boyleja>; APPROVED <20 MAR 2003 by izenbei0>
Review Markings:

Declassified/Released
US Department of State
EO Systematic Review
30 JUN 2005

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: NATIVE
Subject: CCC SITE SURVEY - TUNIS
TAGS: ASEC
To: STATE
Type: TE
Markings: Declassified/Released US Department of State EO Systematic Review 30 JUN 2005